

January 2025			Savannah River	Chelsea WTP	Purrysburg WTP
compound	Units	MRL	Result	Result	Result
PFOS	ng/L	1.9	4.1	4.1	4.4
PFOA	ng/L	1.9	4.4	4.4	4.9
PFNA	ng/L	1.9	<1.9	<1.9	<1.9
PFHxS	ng/L	1.9	<1.9	<1.9	<1.9
PFBS	ng/L	1.9	3.1	3.3	3.6
GenX	ng/L	1.9	<1.9	<1.9	<1.9

February 2025			Savannah River	Chelsea WTP	Purrysburg WTP
compound	Units	MRL	Result	Result	Result
PFOS	ng/L	1.9	3.6	3.7	3.4
PFOA	ng/L	1.9	4.4	4.7	4.1
PFNA	ng/L	1.9	<1.9	<1.9	<1.9
PFHxS	ng/L	1.9	<1.9	<1.9	<1.9
PFBS	ng/L	1.9	2.6	3.3	2.6
GenX	ng/L	1.9	<1.9	<1.9	<1.9

March 2025			Savannah River	Chelsea WTP	Purrysburg WTP
compound	Units	MRL	Result	Result	Result
PFOS	ng/L	1.9	4.6	4.2	4.2
PFOA	ng/L	1.9	4.1	5.1	4.0
PFNA	ng/L	1.9	<1.9	<1.9	<1.9
PFHxS	ng/L	1.9	<1.9	<1.9	<1.9
PFBS	ng/L	1.9	1.9	3.4	1.9
GenX	ng/L	1.9	<1.9	<1.9	<1.9

April 2025			Savannah River	Chelsea WTP	Purrysburg WTP
compound	Units	MRL	Result	Result	Result
PFOS	ng/L	1.9	3.9	4.2	4.6
PFOA	ng/L	1.9	3.8	5.0	4.6
PFNA	ng/L	1.9	<2.0	<1.9	<1.9
PFHxS	ng/L	1.9	<2.0	<1.9	<1.9
PFBS	ng/L	1.9	<2.0	3.1	1.9
GenX	ng/L	1.9	<2.0	<1.9	<1.9

May 2025			Savannah River	Chelsea WTP	Purrysburg WTP
compound	Units	MRL	Result	Result	Result
PFOS	ng/L	1.9	3.1	3.3	3.3
PFOA	ng/L	1.9	3.6	3.9	3.8
PFNA	ng/L	1.9	<2.0	<1.9	<1.9
PFHxS	ng/L	1.9	<2.0	<1.9	<1.9
PFBS	ng/L	1.9	2.5	2.9	2.7
GenX	ng/L	1.9	<2.0	<1.9	<1.9

June 2025			Savannah River	Chelsea WTP	Purrysburg WTP
compound	Units	MRL	Result	Result	Result
PFOS	ng/L	1.9	5.6	4.9	5.8
PFOA	ng/L	1.9	4.3	4.1	4.2
PFNA	ng/L	1.9	<1.9	<1.9	<1.9
PFHxS	ng/L	1.9	<1.9	<1.9	<1.9
PFBS	ng/L	1.9	2.4	2.6	2.3
GenX	ng/L	1.9	<1.9	<1.9	<1.9

July 2025			Savannah River	Chelsea WTP	Purrysburg WTP
compound	Units	MRL	Result	Result	Result
PFOS	ng/L	1.9	4.0	4.8	4.0
PFOA	ng/L	1.9	3.3	4.2	3.5
PFNA	ng/L	1.9	<1.9	<1.9	<1.9
PFHxS	ng/L	1.9	<1.9	<1.9	<1.9
PFBS	ng/L	1.9	2.6	3.3	2.7
GenX	ng/L	1.9	<1.9	<1.9	<1.9

August 2025			Savannah River	Chelsea WTP	Purrysburg WTP
compound	Units	MRL	Result	Result	Result
PFOS	ng/L	1.9	5.6	4.6	5.0
PFOA	ng/L	1.9	3.0	3.9	3.1
PFNA	ng/L	1.9	<1.9	<1.9	<1.9
PFHxS	ng/L	1.9	<1.9	<1.9	<1.9
PFBS	ng/L	1.9	2.1	3.5	2.3
GenX	ng/L	1.9	<1.9	<1.9	<1.9

September 2025			Savannah River	Chelsea WTP	Purrysburg WTP
compound	Units	MRL	Result	Result	Result
PFOS	ng/L	1.9	3.9	4.4	2.2
PFOA	ng/L	1.9	3.6	4.3	3.2
PFNA	ng/L	1.9	<1.9	<1.9	<2.0
PFHxS	ng/L	1.9	<1.9	<1.9	<2.0
PFBS	ng/L	1.9	3.0	3.9	3.1
GenX	ng/L	1.9	<1.9	<1.9	<1.9

October 2025			Savannah River	Chelsea WTP	Purrysburg WTP
compound	Units	MRL	Result	Result	Result
PFOS	ng/L	1.9	4.0	4.2	<1.9
PFOA	ng/L	1.9	4.0	4.3	2.4
PFNA	ng/L	1.9	<1.9	<1.9	<2.0
PFHxS	ng/L	1.9	<1.9	<1.9	<2.0
PFBS	ng/L	1.9	2.7	4.0	2.9
GenX	ng/L	1.9	<1.9	<1.9	<1.9

November 2025			Savannah River	Chelsea WTP	Purrysburg WTP
compound	Units	MRL	Result	Result	Result
PFOS	ng/L	1.9	3.7	3.8	2.8
PFOA	ng/L	1.9	3.4	4.0	3.4
PFNA	ng/L	1.9	<1.9	<1.9	<2.0
PFHxS	ng/L	1.9	<1.9	<1.9	<2.0
PFBS	ng/L	1.9	2.5	3.8	2.9
GenX	ng/L	1.9	<1.9	<1.9	<1.9